

TÜV SÜD  
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service


# CERTIFICATE

No. Z2 076729 0107 Rev. 00

**Holder of Certificate:** **Seraphim Solar System Co.,Ltd.**

No.1-2, Hengyao Rd, Henglin Zhen  
 Wujin District  
 213101 Changzhou  
 PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:**

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 704061801217-00

**Valid until:** 2023-10-16

**Date,** 2018-10-18 ( Zhulin Zhang )





Product Service

# CERTIFICATE

No. Z2 076729 0107 Rev. 00

## Model(s):

SRP-xxx-6MA (xxx=330-360, in step of 5);  
SRP-xxx-6MB (xxx=275-300, in step of 5);  
SRP-xxx-6MA-HV (xxx=330-360, in step of 5);  
SRP-xxx-6MB-HV (xxx=275-300, in step of 5);  
xxx is standing for rated output power at STC.

## Parameters:

Rated Output Power  
at STC: 330 W, 335 W, 340 W, 345 W,  
350 W, 355 W, 360 W, 275 W,  
280 W, 285 W, 290 W, 295 W,  
300 W, 330 W, 335 W, 340 W,  
345 W, 350 W, 355 W, 360 W,  
275 W, 280 W, 285 W, 290 W,  
295 W, 300 W.

Safety Class: Class II

Max. System Voltage: 1000V DC or 1500 V DC

Construction: Framed, with Junction box,  
cable and connector.

Fire Safety Class: Class C according to UL790

PID Test Condition: -1500V and -1000V, 288 h,  
85 % RH, 85°C according to  
IEC TS 62804-1 stress method a).

## Tested according to:

IEC 61215-1(ed.1)  
IEC 61215-1-1(ed.1)  
IEC 61215-2(ed.1)  
IEC 61730-1(ed.2)  
IEC 61730-2(ed.2)  
PPP 58042B:2015

## Production Facility(ies):

076729, 004571, 095290, 098633

TUV SUD  
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證書 ◆ CERTIFICADO ◆ CERTIFICAT